

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7770-1243:103 Page 1 of 1

**CATEGORY:** Valves/Switches

**LISTEE:** NIBCO Inc., 1516 Middlebury St., Elkhart IN 46515-1167  
Contact: \*Charles Stutsman (574) 295-3254 Fax (574) 523-3611

**DESIGN:** Models 505-4/-8 with prefixes T, G, KT or KG; Models KT-505W-4, -8, KG-505W-4, -8 system control ball valves. Models with suffix -4 are without internal switches. Models with suffix -8 have internal supervisory switches. Refer to listee's data sheet for detailed product description and operational considerations.

<b>RATING:</b>	KT-505:	1", 1-1/4", 1-1/2", 2", 2-1/2"	300 psig
	KG-505:	2", 2-1/2"	300 psig

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in manner acceptable to the authorities having jurisdiction. Models with suffix "W" are intended for indoor and outdoor use. All other models are for indoor use only.

**MARKING:** Listee's name, model number, rating and UL label.

**APPROVAL:** Listed as ball valves for use with fire sprinkler systems.

**NOTE:** Formerly 7768-1243:103

\*Rev. 06-06-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 16, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager